


**UNIVERSITY OF TOLEDO
FACILITIES AND CONSTRUCTION**

Section:	Central Control	Procedure Number:	CC-16
Subject:	Thermostat Settings	Effective Date:	May 1995
		Revised Date:	October 2016
Facilities Officer:		Reviewed Date:	February 2023

Standard Operating Procedure

All thermostats will be set to 68-70°(F) during winter months, 73-75°(F) during summer months.

Purpose

Thermostat settings will be as indicated to insure maximum efficiency while maintaining sufficient comfort levels.

Procedure

1. Thermostat settings will be set at 69° during the winter months.
2. Thermostats will be set at 75° during the summer months.
3. Temperatures at 69° October through March, winter months, and 75° April through September, summer months, are considered acceptable.
4. Special consideration will be given where the well being of a patient, or the effected outcome of an experiment may be jeopardized.